


- NOTE:**
- WHERE DOUBLE WYE SERVICE ELEVATION IS LESS THAN 2'-7" BELOW PROPOSED BACK OF CURB, MIN. SLAB ELEV. MUST BE SET TO ALLOW SANITARY SEWER SERVICE.
 - MARK EACH SERVICE END WITH METAL "T" POST PAINTED GREEN.
 - ALL MATERIAL SHALL BE ASTM D3034 SDR26 W/ GASKETS
 - ALL SERVICE CONNECTIONS & EXTENSIONS ARE TO BE INSTALLED WITH THE MAIN LINE CONSTRUCTION.
 - A CLEAN OUT IS REQUIRED AND WILL BE INSTALLED BY THE PLUMBER AT THE ROW FOR EACH SERVICE.
 - LOT CORNERS SHALL BE MARKED WITH A LATH UNDER THE SUPERVISION OF A RPLS UPON COMPLETION OF CONSTRUCTION
 - WHEN SERVICE CONNECTION IS DEEP, CONTRACTOR MUST PLACE A VERTICAL STACK THAT SHALL BE BROUGHT WITHIN 3-1/2 FEET BELOW NATURAL GROUND.



PROFILE



CITY OF COLLEGE STATION SEWER SERVICE LINE CROSSING

DATE
AUG. 2012

**B/CS UNIFIED
STANDARD DETAIL**

DETAIL NO.
S7-00

