


NOTES:

- ① Service saddle, SS straps, CC threads
Installed per manufacturer's
recommendations. All main types:
Smith Blair 317
- ② Corporation Stop: Ford FB 1000-7-Q
(cc thread) - 2"
- ③ Service tubing: Type K copper - cu - soft - 2"
- ④ Ford male adapter - C84-77-Q - 2"
- ⑤ Meter box valve:
5 = Ford Angle Stop - BA-11-777W - 2"
5A = Ford Straight Stop - B11-777W - 2"
- ⑥ Brass nipple I.P.S. - 2" x 3"
- ⑦ Meter Flange - CF31-77 - 2"
- ⑧ Meter box and lid: Old Castle meter box,
CI lid with Reader #36



CITY OF BRYAN
"The Good Life, Texas Style."

CITY OF BRYAN STRAIGHT OR ANGLE TAP - 2"

DATE

JULY 2016

**B/CS UNIFIED
STANDARD DETAIL**

DETAIL NO.

W6-03



CITY OF COLLEGE STATION