


COVER SECTION

BOTTOM VIEW OF COVER


NOTE:

NOTE:
STORM SEWER LIDS TO BE
USED FOR PUBLIC STORM
SEWER SYSTEMS ONLY.
NOT TO BE USED ON PRIVATE
STORM SEWER SYSTEMS.

 \surd MACHINED SURFACE



FRAME SECTION



PICKBAR DETAIL

GENERAL NOTES:

1. BASE THICKNESS AND FOUNDATION SHALL BE AS FOLLOWS:

INLET DEPTH (FT.) (MEASURED FROM FLOWLINE TO FINAL GRADE) BASE THICKNESS 0 - 12 -8" 12 AND OVER-

- 2. DEPTHS GREATER THAN 12' WILL REQUIRE 2 MATS OF REINFORCING STEEL IN THE BASE.
- ALL AREAS WHERE EXISTING VEGETATION AND GRASS COVER HAVE BEEN BARED BY CONSTRUCTION SHALL BE ADEQUATELY BLOCK SODDED OR HYDROMULCHED AND WATERED UNTIL GROWTH IS ESTABLISHED. IN DEVELOPED AREAS WHERE GRASS IS PRESENT, BLOCK SOD WILL BE REQUIRED.
- APPROVED EROSION CONTROL MEASURES MUST BE INSTALLED DURING THE ENTIRE TIME THAT EARTH HAS BEEN BARED BY CONSTRUCTION AND SHALL STAY IN PLACE UNTIL ACCEPTABLE VEGETATIVE GROWTH IS ESTABLISHED AFTER CONSTRUCTION IS COMPLETE AND THEN REMOVED BY CONTRACTOR.

32" DIA. DUCTILE IRON V-1432-3



STANDARD MANHOLE RING AND COVER

DECEMBER 2020

B/CS UNIFIED STANDARD DETAIL DETAIL NO.

D4-00

